

Minutes

10th February, 2020

PRE-BID MEETING FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF AIR-COOLED CHILLERS & ALLIED WORKS AT IUCAA AUDITORIUM

The Pre-bid meeting for Supply, Installation, Testing and Commissioning of Air-Cooled Chillers & Allied Works at IUCAA Auditorium was held on 05th February, 2020 at 1100 hrs in Seminar A-1. The following members were present:

1. Mr.Nitin Ohol
2. Mr.Gajanan Gaikwad
3. Mr.Anand Deshpande – Representative of M/s. Vision EMC Pvt. Ltd.
4. Mr. B.V.Sawant

The queries with responses are enclosed in Annexure – 1. There were total 3 number of representatives from various companies, the list of which is enclosed in Annexure – 2.

B. V. Sawant

Nitin Ohol

G. B. Gaikwad

Anand Deshpande

Annexure – 1

Following are the points discussed in pre-bid meeting on 05.02.2020 at 1100 hrs.

Sr. No.	Name of the agency	Queries	Clarification given by IUCAA
1	M/s.Kirloskar Chillers Pvt.Ltd., Pune- Mr.Aditya Choubey, (8847795703), atc@kcpl.net.in	Whether we can participate in the tender process for Kirloskar make Chillers?	Yes, Kirloskar Chiller make can be accepted. If you are specifications matches with our technical requirement.
2	M/s.Star Air conditioning., Prashant M Kadam (9823334677), bdm@star-airconditioning.com	<p>1.Tender fees- if registered MSME firm. Please elaborate the process.</p> <p>2.Payment terms.</p> <p>3. Factory test of chillers. (Do internal test reports can be furnished as simulation of actual condition cannot be done).</p> <p>4. On Site test of chillers. (At available ambient temp.)</p> <p>5. Do we can propose (22tr x 3 nos chillers working) + (22tr x 1 nos chiller stand by).</p> <p>6.Ambient temp. is considered 42 degrees C do this can be 40 degrees C, as location is Pune of site.</p> <p>7.On dismantle work of old chillers any breakage to ducting etc, will be added in new scope.</p>	<p>1. Tender fees is exempted for the firms registered under MSME/NSIC. But the firm should have valid registration certificate.</p> <p>2. No advance will be paid. Payment will be made only after completion of the work. Please refer Tender term no. 42, Page no. 21/30.</p> <p>3. No, as per Tender conditions actual tests should be carried out at factory and at site are necessary.</p> <p>4. No, as per tender condition test should be carried out at 42 degree C ambient temperature.</p> <p>5.Yes, as per tender condition you can propose 2+1 or 3+1 chiller with same capacity.</p> <p>6. No, the ambient temperature is considered at 42-degree C as per tender.</p> <p>7. No, this is a turnkey project and all work related to dismantling and installing new one is responsibility of the vendor. All cost related to civil, plumbing and electrical will be borne by the vendor only.</p>

		<p>8.Scope of work is only HVAC supported by electrical vendor, civil vendor etc or full turnkey.</p> <p>9.SITC period duration.</p> <p>10.As the site is in use (Auditorium) scope of working will be continues (day and night) or as per schedules suggested by your side (break downs eg :- Saturday Sunday only, in night only etc.)</p>	<p>8. This is a turnkey project and all work related to dismantling and installing new one is responsibility of the vendor. All cost related to civil, plumbing and electrical will be borne by the vendor only.</p> <p>9. As per Tender condition it will be 2 months from the date of LOI/PO.</p> <p>10. All weekdays are allowed during office working hours.</p>
--	--	--	--

Annexure – 2

Sr. No.	Name of the Agency	Name of Representative	Mobile No.
1	M/s.Kirloskar Chillers Pvt.Ltd., Pune	Mr.Aditya Choubey and	8847795703
2	M/s.Star Air conditioning.,	Prashant M Kadam	9823334677

