

Minutes of Technical Committee for SITC of 150 KVA & Scalable upto 200 KVA Modular  
UPS System at IUCAA, Pune

November 02, 2015

The committee constituted by the Director met on September 22, & October 19, 2015 in the Seminar Room A-1. The following members were present –

1. Prof. Tarun Souradeep (Chair)
2. Mr. Nitin Ohol
3. Mr. Gajanan Gaikwad
4. Mr. Vikas Sanghavi (M/S. Vision Electro-Mechanical Consultants Pvt. Ltd.)

The committee scrutinized all the documents submitted by the following vendors -

**1) M/S. Socomec Innovative Solutions Pvt. Ltd. :**

M/S. Socomec Innovative Solutions Pvt. Ltd. has submitted the documents as per our tender conditions. The same were scrutinised and found to be in order as per the tender conditions. Also the vendor has arranged site visits on October 30 & November 02, 2015 at following plants -

- a) Mastercard, Yerawada, Pune - Capacity of UPS - 2 X 120 KVA
- b) Times of India, Main Office, Mumbai - Capacity of UPS - 2 X 120 KVA

The UPS installations at above locations were inspected by the Committee members and found installation works satisfactory. **The technical committee finds M/S. Socomec Innovative Solutions Pvt. Ltd. is satisfying our tender technical requirement & hence considered for further tender process.**

**2) M/S. Novateur Electrical & Digital Systems Pvt. Ltd. :**

M/S. Novateur Electrical & Digital Systems Pvt. Ltd. has submitted the documents as per our tender conditions. The same were scrutinised and found to be in order as per the tender conditions. Also the vendor has arranged site visits on October 30, 2015 at following locations-


- a) IISER, Pune (Physics Dept.) - Capacity of UPS - 1 X 120 KVA
- b) IISER, Pune (Chemistry Dept.) - Capacity Of UPS - 1 X 120 KVA  
(Total 13 Nos. of 120 KVA UPS installed by Vendor in IISER, Pune)

The UPS installations at above locations were inspected by the Committee members and found installation works satisfactory. **The technical committee finds M/S. Novateur Electrical & Digital Systems Pvt. Ltd. is satisfying our tender technical requirement & hence considered for further tender process.**

**3) M/S. Delta Power Solutions (I) Pvt. Ltd. :**

Delta Power Solutions (I) Pvt. Ltd. has submitted the documents as per our tender conditions. The same were scrutinised and found to be in order as per the tender conditions. Also the vendor has arranged site visits on November 02, 2015 at following plants -

- a) Indian Oil Corporation, Mumbai - Capacity of UPS - 2 X 125 KVA
- b) One Point One BPO, Mumbai - Capacity of UPS - 2 X 120 KVA



The UPS installations at above locations were inspected by the Committee members and found installation works satisfactory. **The technical committee finds M/S. Delta Power Solutions (I) Pvt. Ltd. is satisfying our tender technical requirement & hence considered for further tender process.**

**4) M/S. Secure Power India Pvt. Ltd :**

- 1) The vendor is not having minimum dealership period of five years as per Tender Technical Bid Form Point No. 6.
- 2) Attached Purchase/Work Orders are not in the name of Vendor as per Tender Technical Bid Form Point No. 10.
- 3) The vendor do not have Service/Repair Centre in Pune as per Tender Technical Bid Form Point No. 22 (Only Sales Office in Pune).
- 4) Third Party Type Test report are not submitted as per requirement.
- 5) The supporting documents for mentioned technical specifications are not submitted.
- 6) The capacity of given batteries do not fulfil our tender requirement.

**In View of above the technical committee finds that the vendor is not satisfying tender technical requirement and hence not considered for further tender process.**


**5) M/S. Rahi Systems Pvt. Ltd. :**

- 1) The vendor is not having minimum dealership period of five years as per Tender Technical Bid Form Point No. 6.
- 2) Attached Purchase/Work Orders are not in the name of Vendor as per Tender Technical Bid Form Point No. 10. ,
- 3) The vendor do not have Service/Repair Centre in Pune as per Tender Technical Bid Form Point No. 22 (Only Sales Office in Pune).
- 4) Third Party Type Test report are not submitted as per requirement.
- 5) The supporting documents for mentioned technical specifications are not submitted.
- 6) The capacity of given batteries do not fulfil our tender requirement.

**In View of above the technical committee finds that the vendor is not satisfying tender technical requirement and hence not considered for further tender process.**

**6) M/S. Prasa Infocom & Power Solutions Pvt. Ltd. :**

- 1) The vendor's authorised dealership expired on September 30, 2015 & vendor is not a authorised dealer presently as per Tender Technical Bid Form Point No. 5.
- 2) The vendor has not installed modular UPS System of minimum 120 KVA as per Tender Technical Bid Form Point No. 10.
- 3) Third Party Type Test report are not submitted as per requirement.
- 4) The vendor submitted the battery sizing in the original tender as 2 strings of 40 Nos. batteries of 150 AH capacity. When asked for supporting calculation of given battery sizing the vendor has changed the battery sizing to 2 strings of 40 Nos. of 200 AH. Also, the vendor do not clarify/mention if the new revision of batteries attracts any additional cost in the tender.
- 5) The technical specifications of offered UPS system do not match to our tender technical specifications.



In View of above the technical committee finds that the vendor is not satisfying tender technical requirement and hence not considered for further tender process.

7) M/S. Silvex Exports Pvt. Ltd. :

- 1) Attached Purchase/Work Orders are not in the name of Vendor as per Tender Technical Bid Form Point No. 10.
- 2) The vendor do not have Service/Repair Centre in Pune as per Tender Technical Bid Form Point No. 22 (Only Sales Office in Pune).
- 3) Third Party Type Test report are not submitted as per requirement.
- 4) The supporting documents for mentioned technical specifications are not submitted.
- 5) The technical specifications of offered UPS system do not match to our tender technical specifications.

In View of above the technical committee finds that the vendor is not satisfying tender technical requirement and hence not considered for further tender process.

8) M/S. Powertechnics Infosolutions Pvt. Ltd. :


- 1) Attached Purchase/Work Orders are not in the name of Vendor as per Tender Technical Bid Form Point No. 10.
- 2) Third Party Type Test report are not submitted as per requirement.
- 3) The capacity of given batteries do not fulfil our tender requirement.
- 4) The technical specifications of offered UPS system do not match to our tender technical specifications.

In View of above the technical committee finds that the vendor is not satisfying tender technical requirement and hence not considered for further tender process.

In summary, committee recommends M/S. Socomec Innovative Solutions Pvt. Ltd., M/S. Novateur Electrical & Digital Systems Pvt. Ltd. and M/S. Delta Power Solutions (I) Pvt. Ltd. be considered for further tender process since they seem to be technically competent and have submitted all the documents as per our requirements mentioned in the tender.



Nitin Ohol



Vikas Sanghavi



Gajanan Gaikwad



Prof. Tarun Souradeep

(Chairperson)

Technical Committee's recommendations may be approved.

Soman Raychaudhary

DIRECTOR

MA  
24.11.15