

Minutes

November 21, 2013


PRE-BID MEETING FOR INTERIOR WORK AT LABORATORY


The Pre-bid meeting for interior work for laboratory was held on November 21, 2013 at 1500 hrs in the Seminar room A-1 at IUCAA. The following members were present:

1. Mr. Nitin Ohol
2. Mr B.V.Sawant
3. Mr. S.S.Bhujbal

There were 4 representatives of various vendors. The question raised by the vendors and reply given from IUCAA side is enclosed as Annexure -1 and list of present vendors as Annexure -2

It has been decided see the site before submission of the tender. The meeting concluded at 1600 hrs with vote of thanks.


B.V.Sawant


S.S.Bhujbal


Nitin Ohol

Annexure – 1

Clarifications regarding points discussed in Pre-Bid Meeting on 21.11.13 at 1500 hrs

Sr. No.	Name of the Agency	Query	Clarification given by IUCAA
1	M/s Milind Chorrge and Associates :	1) Please clarify the Brand / manufacturers name for item No. 3, 7, 9 or whether we should consider Ergo/ Spacewood make which are mentioned for item No.11 ?	You can quote for B P Ergo/ Spacewood make.
		2) Can you explain the term Rehau edge banding / binding?	Rehau Edge Banding - The edges of 19 or 25 mm thick prelaminated particle board / plywood components of furniture has to be sealed in factory on through feed edge banding machine using jowat make glue and Rehau make edge band of 2.0 mm thickness.
		3) Item no. 5 Solid doors contains viion panel, does it mean vision panel?	Item no 5 - Solid doors with vision panel. "viion" is a typographical error.
		4) Can you please explain item no. 14 tile carpet?	Item no 14 - Tile carpet.- Modular carpet tile from Interface brand. These carpets are in tile size of 500 mm x 500 mm and have been installed at various locations in IUCAA campus.
2	M/s. Colours & Space :	1) Item no. 10 – whether all sides including back is 19 mm plywood?	Yes all the sides and back are with 19 mm plywood
		2) Whether service tax and VAT will be paid extra in the bill amount?	No, Quote should be inclusive of all the taxes.
		3) Clause No. 24 on page no. 21 – The rates quoted will be valid for 12 months – whether agency has to consider this while quoting the rates.	Agency has to quote the rates for this project only. If there is any similar kind of requirement in future, IUCAA will take a consent from the agency before awarding the work.
3	M/s. Prompt Landmarks Pvt. Ltd.	1) What is the glass thickness for item no. 4 i.e. for Vetro make full height partition?	The thickness of the glass partition is 10 mm thick.

[Handwritten signature]

4	AAKAR GEOMATRIX PVT. LTD.	Item No. 4 Please clarify that whether you are looking for fire rated glass partition or normal 12mm thk toughned glass partition.	Our specifications mentioned "VETRO" brand of demountable partitions. We are not looking at any other brand. Saint Gobain product does not fit our specifications. Vendors are be advised to contact "VETRO" for the specifications and details.
---	---------------------------------	---	--

Chung

Tender for Interior work of Laboratory IUCAA

Following representatives attended pre- bid meeting on 21.11.2013 at 1500 hrs

[illegible]